

19955 FALCON AVE-HALE TWP  
-  
PROJECT CONTINUED. FINAL  
SHEET

INSTALL NEW #2  
ACSR ENTIRE  
ROUTE. NEW SPAN  
235' (P12-P16)

RELOCATE/INSTALL  
NEW 40-3 1 PHASE  
TANGENT POLE.  
NEW 1 PHASE  
TAKEOFF. ANCHOR  
ACCORDINGLY.  
25T FUSE  
POI:C57009F01

RELOCATE/INSTALL  
NEW 40-3 1 PHASE  
DE POLE. INSTALL  
NEW 25 KVA XFMR  
AND SPLICE INTO  
EXISTING UG  
SERVICE AND  
EXTEND TO NEW  
POLE.  
POI:B536SY01

SKETCH 2

INSTALL NEW 40-3 1  
PHASE TANGENT  
POLE.


REPLACE EXISTING  
35' POLE WITH 40-3  
DUE TO ROTTEN. 1  
PH DE WITH NEW 25  
KVA XFMR.  
POI:C531SB01

STRING IN NEW 210'  
OF #2 ACSR DUE TO  
TOO MANY SPLICES  
IN EXISTING WIRE.

END OF PROJECT

SURVEY  
-  
TREE  
-  
INSTALLS  
-  
REMOVALS  
-  
RESTORATIONS

SKETCH 3 OF 3

Work Order Information	
Service Request #	:
Design Number	: 000000750591
Designer/Planner ID	: 209179
Designer/Planner Name	: Miller,Troy
Designer/Planner Ph #	: 952-470-3358
Manager Approval	:
Joint Utility	
E:	G:
T:	C:
Design Location	
Division	: Minnetonka
County	: McLeod
City	: HALE TWP
Address	: 19955 FALCON AVE
T: 117N	R: 28W S: 36
Map #	: C57009 Permit :
Electric	
Feeder: LSP022	Voltage: 7200
Phase: A	Bkup Dev ID:
Gas	
System	: Pressure :
Size	: Material :
Dead End	:
Work Order # :	
Date: 02/22/2018	
Sketch: 3 Of 3 Sketch Data	
Scale: 1" equals 222'	
	



CONSTRUCTION USE ONLY

- ☐ NO CHANGES (BUILT AS DESIGNED)  
☐ CHANGES MADE AS INDICATED  
(ALL URD MUST HAVE ACTUAL  
MEASUREMENTS FROM THE FIELD SITE)

RFO \_\_\_\_\_  
FOREMAN \_\_\_\_\_ DATE \_\_\_\_\_  
TEAM LEADER \_\_\_\_\_